



Maura Healey, Governor
Kimberley Driscoll, Lieutenant Governor
Monica Tibbitts-Nutt, Secretary & CEO
Jonathan L. Gulliver, Highway Administrator



December 9, 2024

609078-128111

ADDENDUM NO. 2

To Prospective Bidders and Others on:

NEW MARLBOROUGH
Federal Aid Project No. BFL(BR-OFF)-003S(798)X
Bridge Replacement, N-08-020, Keyes Hill Road over Umpachene River

THIS PROPOSAL TO BE OPENED AND READ: TUESDAY, DECEMBER 10, 2024, AT 2:00 P.M.

Transmitting changes to the Contract Documents as follows:

QUESTION AND RESPONSE:

1 page.

DOCUMENT A00801:

Revised page 152.

Please take note of the above and acknowledge Addendum No. 2 in your Expedite Proposal file before submitting your bid.

Very truly yours,

Eric M. Cardone, P.E.
Construction Contracts Engineer

JPB

cc: Alwin Ramirez Project Manager

*** THIS PAGE IS INTENTIONALLY LEFT BLANK ***

NEW MARLBOROUGH
Federal Aid Project No. BFL(BR-OFF)-003S(798)X
Bridge Replacement, N-08-020, Keyes Hill Road over Umpachene River
(609078-128111)

Question and Response

Addendum No. 2, December 9, 2024

Virgilio Construction Inc. e-mail dated December 6, 2024.

Question 2.) Please confirm that sub-bid item #910 Steel Reinforcement for Structures, is for the Approach slabs as stated on drawing sheet 26, typical abutment section, note #5. The quantity I am getting is more than double the bid quantity of 2,600 LB.

Response 2.) Item 910. Steel Reinforcement for Structures has been revised to 5,800 pounds, see revise page A00801-152.

② Addendum No. 2 December 9, 2024

ITEM 995.01 (Continued)BRIDGE STRUCTURE NO. N-08-020

<u>SUB-ITEM NO.</u>	<u>ITEM</u>	<u>QTY.</u>	<u>UNIT</u>	<u>UNIT PRICE</u>	<u>TOTAL</u>
904.	4000 PSI, ¾ IN., 610 CEMENT CONCRETE	280	CY		
904.3	5000 PSI, ¾ IN., 685 HP CEMENT CONCRETE	365	CY		
904.31	PRECAST HIGHWAY GUARDRAIL TRANSITIONS	4	EA		
910.	STEEL REINFORCEMENT FOR STRUCTURES	5,800	LB		
910.1	STEEL REINFORCEMENT FOR STRUCTURES – EPOXY COATED	33,200	LB		
911.	SHEAR CONNECTORS	70	EA		
912.5	DRILLED AND GROUTED #5 DOWELS	24	EA		
922.1	LAMINATED ELASTOMERIC BEARING W/O ANCHOR BOLT (0-50)	28	EA		
930.304	PRESTRESSED CONCRETE DECK BEAM (S36-21)	288	FT		
930.309	PRESTRESSED CONCRETE DECK BEAM – SPECIAL BEAMS	115	FT		
965.	MEMBRANE WATERPROOFING FOR BRIDGE DECKS	1,160	SF		
970.	DAMP-PROOFING	1,675	SF		
975.1	METAL BRIDGE RAILING (3 RAIL), STEEL (TYPE S3-MTL4)	165	FT		

TOTAL LUMP SUM FOR ITEM 995.01 =