

April 8, 2025

ADDENDUM NO. 3

**ATTLEBORO WATER DEPARTMENT
DOCUMENTS AND SPECIFICATIONS
FOR THE CONSTRUCTION OF THE
WADING RIVER WATER TREATMENT PLANT**

CONTRACT NO. 10

DWSRF NO. 16764



**TATA & HOWARD, INC.
CONSULTING ENGINEERS
67 FOREST STREET
MARLBOROUGH, MASSACHUSETTS**

FILED SUB-BIDS DUE: APRIL 10, 2025, 10:00 AM

GENERAL BIDS DUE: APRIL 24, 2025, 10:00 AM

The following additions and/or alterations to the plans and specifications, for the above referenced contract, are to be incorporated into all bids for the proposed work.

Inclusion of this addendum must be acknowledged on Page 00300-1 of the specification section entitled "FORM FOR GENERAL BID" and Page 00305-1 of the respective "FORM FOR SUB-BID." Failure to acknowledge any and all addenda in the above specified specification section may be cause for rejection of the bid by the OWNER on the grounds that it is not responsive to the "INSTRUCTIONS TO BIDDERS."

GENERAL STATEMENT

- The deadline to submit Filed Sub-Bids remains on Thursday, April 10th, 2025, at 10:00 AM.
- The deadline to submit General Bids remains on Thursday, April 24th, 2025, at 10:00 AM.

QUESTIONS

- Q1. We are in receipt of Addendum #2, which changes the aluminum window specification. In order for the windows to be certified as large missile, they will need to be factory glazed. They cannot be open for glass by others. Additionally, pricing for impact rated windows takes approximately 2 weeks to get pricing on. Additionally, Section 08800 does not have impact rated glass specified. Please consider extending the filed sub-bid for the aluminum windows, changing the spec to have the windows factory glazed and update the glass and glazing specification to have impact glass?
- A1. *The large missile impact testing requirement has been eliminated from the Contract Documents via a change to Specification Section 08520 – Aluminum Windows by this Addendum No. 3. Therefore, the filed sub-bid opening date shall remain the same, and there are no changes to the glass and glazing specification requirements.*

SPECIFICATIONS

1. Reference Specification Section 08520 – Aluminum Windows

Page 08520-2, delete Paragraph 1.05.C.6 revised by Addendum No. 2 and replace with the following:

- “6. Additional test criteria for small or large missile impact is not required.”

END OF ADDENDUM NO. 3